HIMACHAL PRADESH PUBLIC WORKS DEPARTMENT

NO: - PW-AD-DB-Structure Stability /2023-24- 8515

Date: - 25 10 23

To,

The Principal,

Lakshay Public School,

Ward No-2 Joang, Tehsil-Arki

Distt-Solan (H.P.)

Subject:-

To issue Building Safety Certificate.

Reference:-

Your application no nil dated 31.08.2023

Enclosed please find herewith the School Building Safety Certificate of Lakshay Public School, Ward No-2 Joang , Tehsil- Arki , Distt- Solan, H.P. for taking further necessary action.

Encl: -Safety Certificate.

Executive Engineer, Arki Divison, HP, PWD,

Arki

SAFETY CERTIFICATE

The School building of Lakshay Public School, Ward No-2 Joang, Tehsil- Arki, Distt- Solan, H.P. has been inspected by the Junior Engineer concerned section on dated 16.10.2023. As reported by Assistant Engineer Arki Sub Division vide letter no PW/ASD/School Bldg./2023-1059 dated 16.10.2023, it has been observed that no earth quake resistant Provisions have been adopted for this building and no Structure drawings approved by the Competent Govt. Certified Engineer have been produced at the time of inspection. Moreover no assistance was taken from PWD for constructing the building. This structure is a non- engineered structure. Hence the structural Safety of this building cannot be ensured specifically from earthquake resistance point of view. This department will not be held responsible for any type of loss of life and property etc. if this structure fails under any circumstances.

However as per visual inspection the building has been found safe at present only. No Officer/Official of this department will attend plea in any Hon'ble Court of law in case of any dispute. This certificate is valid from **October 2023 to October 2026**. The building has been completed in the year 2003. As per notification received from the Additional Chief Secretary (PW) to the Government of Himachal Pradesh vide letter No PBW (B) E (3) 95/2019 dated 05.05.2021.

Executive Engineer, Arki Divison, HP, PWD,

Arki